

# **Submittal Data Sheet**

Project Name:	
Location:	
Engineer:	
Submitted to:	
Submitted by:	
Reference:	

Approval:
Date:
Construction:
Jnit #:
Drawing #:

#### Performance

Outdoor Unit Model No:	REYQ216PBYD
Туре:	Non-Ducted / Ducted
Rated Cooling Capacity (Btu/hr):	206000
Nom Cooling Capacity (Btu/hr):	216000
Cooling Input Power (kW):	19.07
SEER:	N/A
IEER:	17.2/16.4
Rated Heating Capacity (Btu/hr):	231000
Nom Heating Capacity (Btu/hr):	243000
Heating Input Power (kW):	20.52
Heating COP (Btu/hr / Btu/hr):	3.5/3.3
HSPF:	N/A
Heating COP 17F (Btu/hr / Btu/hr):	2.4/2.3

Condensing Unit Type:	18-Ton VRV-III Heat Recovery
Unit Combination:	REMQ120PBYD REMQ96PBYD
Rated Cooling	Indoor: 80°F DB/67°F WB
Conditions	Outdoor: 95°F DB/75°F WB
Rated Heating	Indoor: 70°F DB/60°F WB
Conditions	Outdoor: 47°F DB/43°F WB
Rated Piping Length (ft)	100 / 50
Rated Height Difference	(ft) 0

### **Condensing Unit Details**

460/60/3ph
L1, L2, L3 Ground
20.5+20.3
30+25
77
(6.1+8.4) x 2
66-1/8
73-1/4
30-1/8
573+573
-

Compressor Type:	Inverter
Capacity Control Range (%):	7 - 100
Capacity Index Limit:	108 - 280.8 (130%)
Airflow Rate (CFM):	7,060+6,530
Gas Pipe Connection (inch):	1-1/8
Liquid Pipe Connection (inch):	5/8
H/L Pressure Connection (inch):	1-1/8
H/L Equalizing Connection (inch):	3/4
Sound Pressure Level (dBA):	62
Sound Power Level (dBA):	
Max. No. of Indoor Units:	37

#### System Details

Refrigerant Type:	R-410A
Holding Refrigerant Charge (lbs):	20.1+19.8
Additional Charge (lbs/ft):	install data
Pre-charge Piping (Length ft):	-
Max. Pipe Length (Total ft):	
Max. Pipe Length (Vertical ft):	164 ft (295 ft) / 295 ft
Max Height Seperation (Ind to Ind ft,	):

23 - 110
0 - 77 / (-4) - 60




# **Submittal Data Sheet**

Project Name:	
Location:	Approval:
Engineer:	Date:
Submitted to:	Construction:
Submitted by:	Unit #:
Reference:	Drawing #:

### **Dimensional Drawing - Condensing Unit**

Daikin AC TRL Generated Submittal Data

REYQ216PBYD



Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006



. . .

# **Submittal Data Sheet**

Project Name:	
Location:	Approval:
Engineer:	Date:
Submitted to:	Construction:
Submitted by:	Unit #:
Reference:	Drawing #:



Daikin AC TRL Generated Submittal Data

(pp) o tan
Date:
Construction:
Unit #:
Drawing #:



Daikin AC (Americas), Inc., 1645 Wallace Drive - Suite 110, Carrollton, TX 75006

(Daikin's products are subject to continuous improvements. Daikin reserves the right to modify product design, specifications and information in this data sheet without notice and without incurring any obligations)