

Submittal Data Sheet

Project Name:			
Location:		Approval:	
Engineer:		Date:	
Submitted to:		Construction:	
Submitted by:		Unit #:	
Reference:		Drawing #:	
Performance			
Outdoor Unit Model No:	REYQ264PBYD	Condensing Unit Type:	22-Ton VRV-III Heat Recovery
	n-Ducted / Ducted		
Rated Cooling Capacity (Btu/hr):	251000	Unit Combination:	REMQ96PBYD REMQ96PBYD
Nom Cooling Capacity (Btu/hr):	264000		REMQ72PBYD
Cooling Input Power (kW):	22.21	Rated Cooling	Indoor: 80°F DB/67°F WB
SEER:	N/A	Conditions	Outdoor: 95°F DB/75°F WB
IEER:	18.7/18.1	Conditions	
Rated Heating Capacity (Btu/hr):	283000	Datad Haating	Indoor: 70°F DB/60°F WB
Nom Heating Capacity (Btu/hr):	297000	Rated Heating Conditions	Outdoor: 47°F DB/43°F WB
Heating Input Power (kW):	25.13	Conditions	
Heating COP (Btu/hr / Btu/hr):	3.4/3.3	Rated Piping Length (ft)	100 / 50
HSPF:	N/A	Rated Height Difference	(ft) 0
Heating COP 17F (Btu/hr / Btu/hr):	2.4/2.3		`
Condensing Unit Details Power Supply (V/Hz/Ph):	460/60/3ph	Compressor Type:	Inverter
	1, L2, L3 Ground	Capacity Control Range	
Min. Circuit Amps MCA (A):	20.3+20.3+16.7	Capacity Index Limit:	132 - 343.2 (130%)
Max. Overcurrent Protection (MOP)(A):	25+25+25	Airflow Rate (CFM):	6,350+6,530+6,530
Max. Starting Current MSC(A):	80	Gas Pipe Connection (inc	
Rated Load Amps RLA (A):	(3.9+8.4) x 2+7.1	Liquid Pipe Connection (I	,
Dimensions Height (Inch):	66-1/8	H/L Pressure Connection	,
Dimensions Width (Inch):	109-7/8	H/L Equalizing Connection	, ,
- ' '	30-1/8	Sound Pressure Level (d	
Dimensions Depth (Inch):	573+573+463	Sound Pressure Level (dBA	
Net Weight (lbs):	373+373+403	Max. No. of Indoor Units:	,
		Max. No. of Indoor Units.	45
System Details			
Refrigerant Type:	R-410A	Cooling Operation Range	, ,
Holding Refrigerant Charge (lbs):	19.8+19.8+18.1	Cooling Range w/Baffle (
Additional Charge (lbs/ft):	install data	Heating Operation Range	, ,
Pre-charge Piping (Length ft):	-	Heating Range w/Baffle (′°F):
Max. Pipe Length (Total ft):			
	ft (295 ft) / 295 ft		
Max Height Seperation (Ind to Ind ft):			




Submittal Data Sheet

Project Name:		
Location:	Approval:	
Engineer:	Date:	
Submitted to:	Construction:	
Submitted by:	Unit #:	
Reference:	Drawing #:	

Dimensional Drawing - Condensing Unit

REYQ264PBYD





Submittal Data Sheet

Project Name:	
Location:	Approval:
Engineer:	Date:
Submitted to:	Construction:
Submitted by:	Unit #:
Reference:	Drawing #:



REYQ264PBYD

Std U.S. Warranty: 7yrs Compressor, 1yrs Parts